



NOTES:

1. Meter to be supplied and installed by City.
2. Meter setters to be equipped with lockable inlet valve, single check outlet valve, and solder clamp and pack joint connection both ends.
3. For 19mm connections preapproved meter setters to be Ford VH92-15 or Ford VH82.
4. For 25mm connections preapproved meter setters to be Ford VH94-15 or Ford VH84.
5. Refer to contract drawings and section 02666 for Detailed Specifications.
6. Refer to MMCD Standard Drawings for detail of service connection to watermain.

Acad 16... (S Tech) L:\Projects_VAN117\A\01\DWG\CURRENT\Wat-2.dwg (Layout1) May 28, 2008 - 2:13pm

			Title: Water Meter for 19mm & 25mm Service Connection	The City of New Westminster
No.	Revision	Approved		Suppl. Drawing No. SDW-2
Scale: N.T.S.		Date: Oct., 2004		