

June 26, 2015

**ADDENDUM #1
NWIT-15-25
Council Chambers Audio-Visual Systems
New Westminster, BC**

This addendum modifies the Tender only as noted:

Addendum # AV-01 – Acumen Engineering

Please see attached Acumen Addendum on Page 2.

END OF ADDENDUM #1


Please acknowledge this addendum in your Tender submission.

Yours truly,

Roy Moulder, SCMP
Purchasing Manager

June 24, 2015

Acumen Addendum



New Westminster City Hall AV Systems NWIT-15-25

Project 7136, File to 8
Addendum # AV01

To	Cc	Company	Attention	Telephone	Email/Fax
X		City Of new Westminster	Roy Moulder	604-527-4509	rmoulder@newwestcity.ca

One Innovation Place
650 – 2700 Production Way
Burnaby, BC, V5A 4X1
T 604 676 9545
F 604 676 9544
acumenengineering.ca

1) Bidders Instruction:

Regarding specified reference products 27 41 16 2.2.16 Wall Mount Wide Angle HD PTZ Camera and 27 41 16 2.2.17 Wall Mount Zoom HD PTZ Camera proponents shall wire the devices with colour coded cabling and connectors.

As per the manufacturers specification the devices require three (3) Cat-5 or Cat-5E cables for the hookup of the camera, and the hookup ports are colour codes as follows:

RS-232 Port – Blue
EZ POWER VIDEO PORT – Orange & Yellow
36VDC For CCU – Red

The installation of cables and connections to these ports shall be labelled and colour coded to match the manufacturers colour coding.

2) 27 41 16 2.3.2 Wireless Hearing Assistance

Current product requirements are:

Wireless Hearing Assistance System:

- .1 Modulation: Wideband FM;
- .2 72 MHz or 216 MHz bandwidth;
- .3 Rack mountable transmitter;
- .4 Wall mount antenna kit;
- .5 Portable RF Digital Receivers (4 minimum) w. Ear Speaker
- .6 Unit to be installed for Council Chambers – wireless antenna to be installed at or near AV production closet door; and
- .7 Reference Product: Listen LS-03



Shall be changed to:

Wireless Hearing Assistance System:

- .1 Modulation: Wideband FM;
- .2 72 MHz or 216 MHz bandwidth;
- .3 Rack mountable transmitter;
- .4 Wall mount antenna kit;
- .5 Portable RF Digital Receivers (4 minimum) w. Ear Speaker
- .6 Unit to be installed for Council Chambers – wireless antenna to be installed at or near AV production closet door; and
- .7 Reference Product: Listen LS-03 c/w rechargeable batteries for receiver units and LA-321 8 unit Portable Charging/Carrying Case.

Regards,
Andrew Meissner, BA, CTS
Technology Consultant
Acumen Engineering

This Addendum forms part of the Contract documents and is to be read, interpreted and coordinated with all other parts. The cost of all work contained herein is to be included in the bid price. The following revisions supersede the information contained in the original drawings and specifications issued for the above mentioned project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Bid Form. Failure to do so may subject the bidder to disqualification.