



NEW WESTMINSTER

September 23, 2015

ADDENDUM #3
NWIT-15-34
Anvil Centre Interior Alterations
Anvil Centre, New Westminster, BC

This addendum modifies the Invitation to Tender only as noted:

ADDITIONAL INFORMATION

Please refer to Addendum No. 2 from David Norman Architecture Inc, (3 pages following)

Please acknowledge this addendum on page 2 of 4 in the Bid Form.

END OF ADDENDUM #3

Yours truly,

Roy Moulder, SCMP
Purchasing Manager

ADDENDUM NO. 2

1. INTENT

This addendum is issued prior to signing of the contract to provide for certain provisions to and clarifications of the work and contract documents. Execute work required by this addendum in accordance with applicable drawings and specifications.

2. DRAWINGS

2.1 Refer to Drawing A5.3 – MILLWORK GLASS DOOR DETAILS.

- Revise the tempered glass door thickness from 4mm to 5mm.
- Revise the number of glass door hinges (hinge model BP 75340170) from 2 per door to 3 per door.

3. SPECIFICATIONS

not applicable

4. ATTACHMENTS

not applicable

END OF ADDENDUM