



# NEW WESTMINSTER

October 4, 2022

**ADDENDUM #2**  
**NWIT-22-18**  
**Queensborough Ecological Restoration**  
**New Westminster, BC**

This addendum modifies the Invitation to Tender only as noted:

**CLARIFICATIONS**

- Q1 What size should the rip rap be for the on the rip rap lookout?  
A1 The rip-rap size should vary between 1-3 feet in diameter, well-graded, and a mixture of rock sizes rather than rocks of a uniform size. The rock must be locally sourced material.
- Q2 What type of growing medium is required for the hydroseed areas?  
A2 The Growing media for hydroseed areas should be the Canadian Landscape Standard Level 5 designation 3P for meadow planting areas
- Q3 What type of growing medium is required for the forest planting zone?  
A3 The growing media for the forest planting zone should be the Canadian Landscape Standard Level 5 designation 4P (restoration) for forest planting areas
- Q4 What type of growing medium is required for the pond planting zone?  
A4 The growing media for the pond planting zone should be the Canadian Landscape Standard designation 4P (aquatic) for pond planting areas
- Q5 What type of growing medium is required for the submergent planting zone?  
A5 The growing media for the submergent planting zone should be the Canadian Landscape Standard designation 4P (aquatic) for submergent planting areas
- Q6 What type of growing medium is required for the naturalized planting zone?  
A6 The growing media for the naturalized planting zone should be the Canadian Landscape Standard designation 4P (restoration) for naturalized planting areas
- Q7 Are we to carry an arborist in our pricing for this work or will this be provided by the city?  
A7 The City will provide an arborist to review all arboriculture work.

Q8 What spec is required on the lumber for the trail sign posts?

A8 6x6 D & better Clear Western Red Cedar

Q9 If we have to provide our own posts for the bat boxes and swallow posts, what type and spec of post are you looking for on these?

A9 Posts for the bat boxes and swallow platforms should be 4"x 6" untreated, unpainted wood, preferably cedar, pine, or cypress. Knotty or clear lumber is acceptable.

Q10 Supplier of the Rosetta Irregular steps said that their steps come in pallets of 6 with 6 different sizes. You cannot break up the pallets and order just one size on these. The specifications in the tender document call for steps that are sized 1219x711x178mm. Are you able to confirm that it is fine to have steps that all vary in size? On a side note, they do sell Rosetta dimensional steps where you can get consistent sizes on a pallet

A10 The Rosetta Irregular steps with mixed sizes is the intended product. The size indicated on the drawings can be replaced with the 6 sizes indicated on the manufacturer's website.

Please acknowledge this addendum as directed in the Bid Form.

**END OF ADDENDUM #2**

Yours truly,



Heather Rossi  
Intermediate Buyer