



NEW WESTMINSTER

October 22, 2014

ADDENDUM #4
NWRFP-14-25
Electrical Utility Distribution System Plan
New Westminister, BC

This addendum modifies the Request for Proposal only as noted:

ADDITIONAL INFORMATION (Answers to submitted questions)

- Q1 For SOW of section 6.1 a) Summary of the Existing Electrical Utility, the City expects (among other things) a review of load forecasting, planning, designing and operation processes. Please confirm if the City is expecting process improvement recommendations as well.
- A1 Recommendations are not necessary for this section, but the Utility is interested in any recommendations that could add value or efficiency to its operations.
- Q2 Load demand at each transformer will be required. Is the utility billing data (kWh) linked to the transformer number/ID?
- A2 The Utility billing system is not tied into the GIS or any utility equipment database. Load demand for transformers would need to be determined manually.

Please acknowledge this addendum in your Proposal.

END OF ADDENDUM #4

Yours truly,

Heather M. Rossi
Intermediate Buyer
email: hrossi@newwestcity.ca