



NEW WESTMINSTER

November 10, 2015

ENQUIRES AND RESPONSES #2
NWRFP-15-28
Engineering Services,
Wood Street Drainage Pump Station Replacement
New Westminster, BC

ANSWERS TO SUBMITTED QUESTIONS

- Q1 The first item under geotechnical scope is not clear. The RFP states that the station design is to meet provincial seismic guidelines for flood protection and dyke upgrades. The site plan and air photos show the pump station is setback from the dyke. Can the City please clarify the design requirements for the pump station in this regard?
- A1 The new pump station, whether it would be closer to the dyke or not, shall be designed to meet provincial seismic guidelines for flood protection. In addition, the geotechnical firm shall assess a section of the dyke, in front of the pump station, and make recommendations for improving flood protection, if required

Yours truly,

A handwritten signature in blue ink, appearing to read "Heather M. Rossi".

Heather M. Rossi
Intermediate Buyer