



NEW WESTMINSTER

June 26, 2020

**ADDENDUM #1
NWRFP-20-13
Construction of Westminster Pier Park Play Area
New Westminster, BC**

This addendum modifies the Request for Proposal only as noted:

TITLE PAGE

Closing Time:

<CHANGE TO READ> **“Thursday, July 9, 2020”**

PART 3 PROPOSAL FORMAT AND CONTENT REQUIREMENTS

1.0 Proposal Cover Page

Closing Time:

<CHANGE TO READ> **“Thursday, July 9, 2020”**

ALTERNATE APPROVAL

The City advises that Kelowna Safety Surfacing Inc. is an acceptable alternate supplier for the poured in place rubber safety surfacing.

ADDITIONAL INFORMATION

The existing Westminster Pier Park concrete multiuse path south of the play area is vehicle rated up to a weight limit of 10,000 kg. Contractor shall not overload the path for any reason and make good any damage to this path or any existing park elements

Please acknowledge this addendum in your Proposal.

END OF ADDENDUM #1

Yours truly,

Heather M. Rossi
Intermediate Buyer