



NEW WESTMINSTER

August 31, 2022

ENQUIRIES AND RESPONSES # 1
NWRFP-22-13
Remove and Replace Fencing - Baseball Diamond 2
Queen's Park, New Westminster, BC

ANSWERS TO SUBMITTED QUESTIONS

Q1 Are we required to supply hoarding fence prior to the start of the work? (APPENDIX E 18.1)

A1 Yes, only if necessary. Based on the site location and activity, vendor should carefully consider the need for hoarding fence.

Q2 Are we required to obtain a permit, supply, and install tree protection fencing prior to start of the work? (PART 1 9.8 D)

A2 Yes, if necessary, although most of the area should be outside the tree canopy area due to the existing fencing.

Q3 Are we required to install a concrete mow strip along the fence line as part of the contract? Or is this by others? (3.2.1)

A3 No

Q4 Is the mesh required to be tack welded in lieu of ties? (3.4.1)

A4 No, only at all post connection points, hardware harness, etc. Mesh are to be tied based on the spacing specified in the document.

Q5 2.1.8 notes wirer/hog rings at 6" o.c., and 3.6.4 notes wire/hog rings not to exceed 4". Does 3.6.4 supersede 2.1.8?

A5 Correct.

Q6 (PART 1 9.8 B) Non-road diesel emissions regulations bylaw. This line item notes registration is required to operate tier 0 or tier 1 non road diesel engines within Metro Vancouver. It also notes the City, at its discretion, may give preference to equipment that meets higher emission standards. Would the use of a bobcat for the digging of the large post holes be exempt from this registration?

A6 Yes

Q7 What is the start date of this project?

A7 As early as possible, noting weather changes are soon ahead and field conditions will soften.

END of Enquiries and Responses

Yours truly,

A handwritten signature in blue ink, appearing to read "Heather Rossi". The signature is written in a cursive style with a large initial 'H'.

For
Heather Rossi
Intermediate Buyer
City of New Westminster