


TYPICAL POST-TOP DECORATIVE PATHWAY POLE ELEVATION
1:50

- LEGEND**
- * PROPOSED POST-TOP DECORATIVE PATHWAY POLE (4.6M 70W HPS) IES TYPE 2 OPTICS C/W DOMUS DMS50 LUMINAIRE AND CLEAR LAMP
 - ⊕ PROPOSED ENTRY ARBOUR LUMINAIRE, B-K LIGHTING DELTA STAR SERIES (DS-8-BLW-10-11-A) MOUNTED ON MB-2 BOX C/W COVER (BC1-BLW) AND TRANSFORMER (TRSS75-120)
 - ⊕ PROPOSED DUPLEX GFCI RECEPTACLE C/W LOCKABLE RECEPTACLE ENCLOSURE
 - A & C LUMINAIRE/RECEPT ON RED PHASE CONDUCTOR
 - B & D LUMINAIRE/RECEPT ON BLACK PHASE CONDUCTOR
 - ⊕ PROPOSED SERVICE / IRRIGATION KIOSK (REFER TO SHEET 02 FOR DETAILS)
 - J PROPOSED LARGE RECTANGULAR PLASTIC JUNCTION BOX 2 SECTIONS DEEP C/W GREEN PLASTIC LID (WEST COAST ENGINEERING #25100 C/W #25500 LID)
 - PROPOSED RPVC CONDUIT AND CONDUCTORS
 - PROPOSED STUB OUT AND CAP 50mm RPVC FOR FUTURE EXTENSION (CAP END & MARK LOCATION)

- NOTES**
1. ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE MMCD SECTION 16550, THE CITY OF NEW WESTMINSTER STANDARDS AND SPECIFICATIONS, CURRENT ISSUE, AND THE CANADIAN ELECTRICAL CODE AND ALL AMENDMENTS AS ISSUED BY THE ELECTRICAL SAFETY BRANCH.
 2. CONTRACTOR TO NOTIFY PROVINCIAL AND MUNICIPAL INSPECTORS 48 HOURS PRIOR TO COMMENCEMENT OF U/G AND ELECTRICAL WORK.
 3. A TRON HEB SERIES WATER RESISTANT FUSEHOLDER C/W 10A BUSS KTK 10 FUSE, OR APPROVED EQUAL AND TWO TYPE 'L' INSULATING BOOTS SHALL BE INSTALLED IN EACH LUMINAIRE LIVE CONDUCTOR IN THE HANDHOLE.
 4. CONDUCTORS INSIDE POLE SHALL BE:
 - 2 No.10 RW90 — 30mm RPVC (UNLESS OTHERWISE NOTED)
 - 1 No.12 RW90
 5. ALL COMMON CIRCUIT WIRING SHALL BE TAGGED & TY-RAPPED AS DETAILED IN THE MMCD.
 6. ALL CONDUCTORS SHALL BE STRANDED COPPER, TYPE RW90 INSULATED AND COLOUR CODED.
 7. POLES SHALL BE HOT DIPPED GALVANIZED.
 8. EXACT POSITION OF ALL EQUIPMENT WILL BE LAYED OUT BY THE CONTRACTOR & CONFIRMED BY DMD & CITY IN THE FIELD.
 9. PROVIDE PULL STRINGS IN ALL EMPTY CONDUITS.
 10. CONTRACTOR SHALL SUBMIT POLE, LUMINAIRE, BALLAST AND LAMP SHOP DRAWINGS TO DMD PRIOR TO EQUIPMENT ORDERING.
 11. LAMPS SHALL BE TESTED AND APPROVED BY BALLAST MANUFACTURER AS SUITABLE FOR ELECTRONIC BALLAST OPERATION. SUPPLY ONE EXTRA BALLAST AND 6 EXTRA LAMPS TO CNW MAINTENANCE DEPARTMENT.
 12. CONTRACTOR SHALL KEEP A RECORD OF ALL ELECTRICAL INSTALLATION ON DEDICATED SET OF DRAWINGS AND SUBMIT AS BUILT INFORMATION TO ELECTRICAL CONSULTANT (DMD AND ASSOCIATES LTD.) WITHIN 2 WEEKS AFTER END OF CONSTRUCTION. THIS IS A CONDITION OF SUBSTANTIAL PERFORMANCE.
 13. CONTRACTOR SHALL LOCATE AND AVOID ALL UNDERGROUND SERVICES.
 14. SECURITY HANDHOLE COVER C/W TAMPER PROOF BOLTS TO BE INSTALLED ON ALL POLES.
 15. THE CONTRACTOR SHALL CONFIRM EXACT SERVICE LOCATION WITH THE CITY OF NEW WESTMINSTER PRIOR TO CONSTRUCTION.
 16. EACH CONCRETE BASE SHALL HAVE A 20mm x 3.0m LONG GALVANIZED GROUND ROD.
 17. REFER TO LANDSCAPE DRAWINGS FOR ADDITIONAL DETAILS.

NOT FOR CONSTRUCTION
2010-08-27

CHECK BEFORE YOU DIG
CONTRACTOR SHALL REFER TO MUNICIPAL RECORD / CIVIL DESIGN DRAWINGS FOR ALL OTHER UTILITIES, SERVICE LOCATIONS, AND DETAILS. THE EXACT LOCATION OF THESE UTILITIES SHALL BE DETERMINED ON SITE BY THE CONTRACTOR.



DMD & Associates Ltd.
#12-17358 104A Avenue
Surrey, BC, Canada V4N 5M3
www.dmdeng.com 604/589-9010
office@dmdeng.com Fax 604/589-9012

DESIGNED	DAVID SON
DRAWN	MARLON ELBO
CHECKED	DANIEL J. WONG
DATE	AUGUST 05/2010
SCALE:	AS SHOWN
SEAL	

No.	DATE	BY	CHKD	REVISION
-	2010-08-10	MT	DS	ISSUED FOR REVIEW
-	2010-08-20	ME	DS	ISSUED FOR TENDER
1	2010-08-27	ME	DS	ADDENDUM

PWL Partnership Landscape Architects Inc.
500-1201 West Pender Street Vancouver, BC V6E 2B2 Tel: (604) 688-6111

PARK LIGHTING & ELECTRICAL
NEIGHBOURHOOD PARK
EWEN AVENUE AND DERWENT WAY
NEW WESTMINSTER, BC

PROJECT No.	SHEET No.	REVISION
3167-10-01 of 04	1 of 4	1

